

Date: 01/11/2019

University of Maine System  
Neville Hall  
Orono, Maine 04469

RE: Application number A-2018-1493  
Licensee reference number: A-OLDTOWN-CORE

Dear Debbie Brill:

Enclosed, please find Form 4, Authorization for Pole Make-Ready Work.

Please sign this form and return it with your check made payable to **Consolidated Communications** in the amount of **\$8,693.70**. This amount due is for the Make-Ready Work associated with the application number referenced above in the vicinity of Stillwater Ave, Center St., Maine 43, various, Old Town, ME.

Please note: If payment is not received by 02/10/2019 the application will be canceled and you will need to reapply.

**\*\*\* It is your responsibility to notify and coordinate all transfers/moves with all other third party attachees - attachees are listed on the form 3 (list may not be complete). Please notify CCI construction upon their completion. Any delay in their transfers may delay your license.**

Please call 1-866-774-5228 to speak with a License Administration Associate should you have any questions.

Please submit payment to:

Fairpoint Communications  
License Administration Group  
5 Davis Farm Rd  
Portland, ME 04103

Sincerely,

Jami Godin  
License Administration

Attachments

A-2018-1493

Form 4

**AUTHORIZATION FOR POLE MAKE-READY WORK**

Licensee: **University Of Maine Systems**

Field survey work associated with your License Application No. **A-OldTown-Core** **October 4, 2018**  
for attachments to poles in the municipality of **Old Town**, State of **ME** has been completed.  
Following is a summary of the make-ready charges which will apply:

TASK #	QUANTITY	UNIT COST	TOTAL COST
11A	1	\$258.50	\$258.50
11B	1	\$85.80	\$85.80
14A	8	\$253.00	\$2,024.00
21A	35	\$152.90	\$5,351.50
21B	1	\$33.00	\$33.00
26	2	\$264.00	\$528.00
Work Order Preparation			\$312.00
UNDERPAID SURVEY			\$100.90

Attached as requested, is an itemized unit cost (Form 3) of required make-ready work and associated charges. If you wish us to complete the required make-ready work, please sign this copy below and return with an advance payment in the amount of **\$8,693.70**

Licensors Name (Print) **Consolidated Communication**

Signature *William L Francini*

Title **Outside Plant Engineer**

Address **5 Davis Farm Rd  
Portland, Mw 04103**

Telephone Number **207-991-4598**

Date **January 11, 2019**

The replacements and rearrangements included in Pole Attachment License Application No. **A-OldTown-Core** are authorized and the costs therefore will be paid to Licensors in accordance with Appendix I to Pole Attachment License Agreement. My check is attached.

Licensee's Name (Print)

Signature \_\_\_\_\_

Telephone Number

Title

Date \_\_\_\_\_

**FIELD SURVEY / MAKE READY WORK FORM**

RCE to Complete - Total Poles Surveyed **132** Total Poles Requiring Make Ready CCI **17** Others **0**

Surveyors: **BILL FRANCINI** Survey Date: **12/19/18** Survey Order # **MEA20181493APP**

CCI **BILL FRANCINI** Munic: **Old Town** State: **Maine** Exch Code: **7119** Munic Code: **7119901**

Licensee **Debbie Brill** Licensee Name: **University Of Maine Systems** Licensee Application # **A-OldTown-Core**

Elco **Brian Gray** Elco Name: **Emera Maine** LAG Application # **A-2018-1493** days

Location		Pole #	Attach	Ownership						Description of Work	CCI	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	EI	F/C PS	J.O.		J.U.		S.O.						
				Tel	EI	Tel	EI	Tel	EI					
Rte 6 / Stillwater Ave	62	NT	F	X						No make ready work required; UMS pl anc & d'd end guy; attach 12" below CCI				*
Rte 6 / Stillwater Ave	61	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	60	NT	F	X						No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	59	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	58	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	57	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	56	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	55	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	54	NT	F	X						No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	53	NT	F	X						No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	52	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	51	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	50	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	49	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*

Location	Pole #	Attach			Ownership						Description of Work	CCI	Others	Tasks	Attach location see notes
		Tel	El	F/C PS	J.O.		J.U.		S.O.						
					Tel	El	Tel	El	Tel	El					
Rte 6 / Stillwater Ave	48	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	47	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	46	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	45	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	44	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	43	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	42	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	41	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	40	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	39	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	38	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	37	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	36	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	35	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	34	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	33	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	32	NT	F	X							No make ready work required; UMS attach 12" below CCI				*

Location	Pole #	Attach	Ownership								Description of Work	CCI	Others	Tasks	Attach location see notes
			F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 6 / Stillwater Ave	31	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Stillwater Ave	30	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	29	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	28	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	27	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	26	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	25	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	24	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	23	NT	F	X							No make ready work, guying required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	23S	NT	F	X							No make ready work, guying required; UMS attach 12" below CCI				*
Stillwater / Stillwater Ave	32	NT	F	X							No make ready work, guying required; UMS attach 12" below CCI				*
Stillwater / Stillwater Ave	32S	NT	F	X							No make ready work, guying required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave (no p.22)	21	NT	F	X							No make ready work, guying required; UMS attach 12" below CCI				*
Rte 6 / Stillwater Ave	20	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	19	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	18	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	17	NT	F	X							No make ready work required; UMS attach 12" below CCI				*

Location	Pole #	Attach	Ownership								Description of Work	CCI	Others	Tasks	Attach location see notes
			F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 6 / Center St	16	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	15	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	14	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	13	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	12	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Rte 6 / Center St	11	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	10	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	9	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	8	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	7	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	6	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	5	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St	4	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 6 / Center St (Intersection of Fourth St)	3	264604	F	X							Emera repl 3 wire sec'd w/triplex: p.2-p.3; CATV raise cable 24"; MFC raise cable 24" CCI raise 2 cables, 1 pmt (and to side of pole) 24"; UMS attach 12" below CCI	X	X	11A, 11B, 14A	*
Rte 6 / Center St	(NT) 2	204675	F	X							CCI move pmt stub to side; Stencil UMS attach 12" below CCI	X		21A	*
Rte 6 / Center St	1	204652	F	X							CCI move pmt to side of pole; UMS attach 12" below CCI	X		14A	*

Location	Pole #	Attach	Ownership								Description of Work	CCI	Others	Tasks	Attach location see notes
			F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 6 / Center St	1/2	204651	F	X							No make ready work required; UMS attach 12" below CCI				*
S Brunswick St / Brunswick St (At corner of Center St)	1/2	102701	F	X							No make ready work required; UMS attach 12" below CCI				*
S Brunswick St / Brunswick St	(NT) 1	204709	F	X							CCI move 1 pmt, 1 wire term to side of pole; Stencil UMS attach 12" below CCI	X		14A, 21A	*
S Brunswick St / Brunswick St	2	204710	F	X							No make ready work required; UMS attach back side of pole & below CCI				*
Rte 1 / Center St	1	204673	F	X							No make ready work required; UMS attach 12" below CCI				*
Rte 1 / Center St	(NT) 2	204671	F	X							CCI move 2 wire terminal to side; Stencil UMS attach 12" below CCI	X		21A, 21B	*
Rte 1 / Center St	(NT) 3	204606	F	X							No make ready work, d'd end guy required; Stencil UMS attach 12" below CCI	X			*
TS 247A / Fourth St t/o pole: Rte 6, p.3 / Center St	1	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
TS 247A / Fourth St	2	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
TS 247A / Fourth St	3	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
TS 247A / Fourth St	4	NT	F	X							CCI move pmt to side of pole; UMS attach 12" below CCI	X		14A	*
Fourth St	NT	264637	F								SOLELY OWNED EMERA POLE - DO NOT LICENSE -				*
TS 247A / Fourth St	6	NT	F	X							No make ready work, guying required; UMS attach 12" below CCI				*
TS 247A / Fourth St	7	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
TS 247A / Fourth St	8	NT	F	X							No make ready work, d'd end guying required; UMS attach 12" below CCI				*
Middle St / Middle St	4	NT	F	X							No make ready work required; DBU attach back side of pole and below CCI				*
Middle St / Middle St	3	NT	F	X							No make ready work required; UMS attach 12" below CCI				*

Location	Pole #	Attach	Ownership								Description of Work	CCI	Others	Tasks	Attach location see notes
			F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Middle St / Middle St	2	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Middle St / Middle St	1	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Shirley St / Shirley St	5	NT	F	X							No make ready work required; UMS slack span from Middle p.3 - Shirley p.5; attach 12" below CCI				*
Shirley St / Shirley St	4	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Shirley St / Shirley St	3	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
Shirley St / Shirley St	2	NT	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
Shirley St / Shirley St	1	NT	F	X							No make ready work, d'd end guying required; UMS attach 12" below CCI				*
N Water St / Water St	1DD	275328	F	X							No make ready work, d'd end guying required; UMS attach 12" below CCI				*
N Water St / Water St	NT	275307	F							X	SOLELY OWNED EMERA POLE - DO NOT LICENSE -				*
N Water St / Water St	1	275350	F	X							CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*
N Water St / Water St	2	275325	F	X							CCI move wire terminal to side of pole; Stencil UMS attach 12" below CCI	X		21A	*
S Water St / Water St	1	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
S Water St / Water St	2	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
S Water St / Water St	3	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
S Water St / Water St	4	NT	F	X							No make ready work required; UMS attach 12" below CCI				*
S Water St	NT	270618	F							X	SOLELY OWNED EMERA POLE - DO NOT LICENSE -				*
S Water St	NT	275310	F							X	SOLELY OWNED EMERA POLE - DO NOT LICENSE -				*



Location Tel Rte / Street Name	Pole # Tel	Attach El	F/C PS	Ownership						Description of Work	CCI	Others	Tasks	Attach location see notes
				J.O.		J.U.		S.O.						
				Tel	El	Tel	El	Tel	El					
S Water St	NT	275311	F						X	SOLELY OWNED EMERA POLE - DO NOT LICENSE -			*	
S Water St	NT	275316	F						X	SOLELY OWNED EMERA POLE - DO NOT LICENSE -			*	
N Brunswick / Brunswick St t/o pole: S brunswick St, p.½	1	100464	F	X						No make ready work required; DBU attach back side of pole and below CCI			*	
N Brunswick / Brunswick St	2	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	3	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	4	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	5	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	6	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	7	NT	F	X						No make ready work required; DBU attach back side of pole and below CCI			*	
N Brunswick / Brunswick St	8	NT	F	X						No make ready work required; DBU attach back side of pole and below CCI			*	
N Brunswick / Brunswick St	8½	NT	F	X						No make ready work required; DBU attach back side of pole and below CCI			*	
N Brunswick / Brunswick St	9	NT	F	X						CCI move 1 pmt, 1 wire terminal to side of pole; UMS attach 12" below CCI	X	14A, 21A	*	
N Brunswick	NT	275277	F						X	SOLELY OWNED EMERA POLE - DO NOT LICENSE -			*	
N Brunswick / Brunswick St	10	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	11	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X	21A	*	
N Brunswick / Brunswick St	12	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	
N Brunswick / Brunswick St	12½	NT	F	X						No make ready work required; UMS attach 12" below CCI			*	

Location	Pole #	Attach		Ownership						Description of Work	CCI	Others	Tasks	Attach location see notes	
		Tel	El	F/C PS	J.O.		J.U.		S.O.						
					Tel	El	Tel	El	Tel						El
N Brunswick / Brunswick St	13	NT	F	X						No make ready work, guying required; UMS attach 12" below CCI				*	
Stillwater / Stillwater Ave	6	NT	F	X						No make ready work, d'd end guying required; UMS attach 12" below CCI				*	
Stillwater / Stillwater Ave	5	NT	F	X						No make ready work required; UMS attach 12" below CCI				*	
Stillwater / Stillwater Ave	NT	NT								CANCEL PER LINCENSEE					
Stillwater / Stillwater Ave	4	269698	F	X						No make ready work required; DBU attach back side of pole and below CCI				*	
Stillwater / Stillwater Ave	3	269696	F	X						CCI move pmt stub to side; Stencil UMS attach 12" below CCI	X		21A	*	
Stillwater / Stillwater Ave	2	NT	F	X						No make ready work required; UMS attach 12" below CCI				*	
Stillwater / Stillwater Ave	1	269687	F	X						No make ready work required; UMS attach 12" below CCI				*	
Rte 8 / Main St	13	NT	F	X						No make ready work required; UMS attach 12" below CCI				*	
Rte 8 / Main St	13S	NT	F	X						No make ready work, d'd end guying required; UMS attach 12" below CCI				*	
Rte 8 / Main St	12	269726	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*	
Rte 8 / Main St	11	NT	F	X						CCI move pmt to side of pole; guying required; UMS attach 12" below CCI	X		14A	*	
Rte 8 / Main St	11S	NT	F	X						No make ready work, guying required; UMS attach pole 12" below CCI				*	
Rte 8 / Main St	10	NT	F	X						CCI move pmt stub to side; guying required; UMS attach 12" below CCI	X		21A	*	
Rte 8 / Main St	10S	NT	F	X						No make ready work, guying required; UMS attach pole 12" below CCI				*	
Rte 8 / Main St	(6) 9	269677	F	X						CCI move pmt to side of pole; Restencil; UMS attach 12" below CCI	X		14A	*	
Rte 8 / Main St	8	NT	F	X						CCI move pmt stub to side; UMS attach 12" below CCI	X		21A	*	

Location	Pole #		Attach	Ownership						Description of Work	CCI	Others	Tasks	Attach location see notes	
	Tel	EI		F/C PS	J.O.		J.U.		S.O.						
					Tel	EI	Tel	EI	Tel						EI
Rte 8 / Main St	7	NT	F	X						No make ready work required; UMS attach 12" below CCI				*	
Rte 8 / Main St	6	269711	F	X						CCI move pmt to side of pole; UMS attach 12" below CCI	X		14A	*	
Rte 8 / Main St	5	269708	F	X						No make ready work, d'd end guying required; UMS attach 12" below CCI				*	
Totals				127	0	0	0	0	5		17	0			

Notes:

\* Attach no closer than 40" below power attachment and 12" below CCI's attachment.